



GT01-RS4-M

Serial Multi-Drop Connection Unit

User's Manual

GRAPHIC OPERATION TERMINAL GOT1000	Manual Number	JY997D35801K
	Date	Nov. 2025

This manual describes the specifications of the product. Before use, read this manual and manuals of relevant products fully to acquire proficiency in handling and operating the product. Make sure to learn all the product information, safety information, and precautions.

And, store this manual in a safe place so that you can take it out and read it whenever necessary. Always forward it to the end user.

Registration

The company name and the product name to be described in this manual are the registered trademarks or trademarks of each company.

Effective Nov. 2025

Specifications are subject to change without notice.

© 2009 MITSUBISHI ELECTRIC CORPORATION

Safety Precaution (Read these precautions before using.)

Before using this product, please read this manual and the relevant manuals introduced in this manual carefully and pay full attention to safety to handle the product correctly.

The precautions given in this manual are concerned with this product.

In this manual, the safety precautions are ranked as "WARNING" and "CAUTION".

	Indicates that incorrect handling may cause hazardous conditions, resulting in death or severe injury.
	Indicates that incorrect handling may cause hazardous conditions, resulting in medium or slight personal injury or physical damage.

Depending on circumstances, procedures indicated by "CAUTION" may also be linked to serious results.

In any case, it is important to follow the directions for usage.

DESIGN PRECAUTIONS		WARNING
<ul style="list-style-type: none"> Some failures of the Multi-Drop Connection Unit or cable may keep the outputs on or off. An external monitoring circuit should be provided to check for output signals which may lead to a serious accident. Not doing so can cause an accident due to false output or malfunction. If a communication fault (including cable disconnection) occurs during monitoring on the GOT, communication between the GOT and PLC CPU is suspended and the GOT becomes inoperative. A system where the GOT is used should be configured to perform any significant operation to the system by using the switches of a device other than the GOT on the assumption that a GOT communication fault will occur. Not doing so can cause an accident due to false output or malfunction. Do not use the Multi-Drop Connection Unit as the warning device that may cause a serious accident. An independent and redundant hardware or mechanical interlock is required to configure the device that displays and outputs serious warning. Failure to observe this instruction may result in an accident due to incorrect output or malfunction. 		

DESIGN PRECAUTIONS		CAUTION
<ul style="list-style-type: none"> Do not bundle the control and communication cables with main-circuit, power or other wiring. Run the above cables separately from such wiring and keep them a minimum of 100mm (3.94in.) apart. Not doing so noise can cause a malfunction. 		

MOUNTING PRECAUTIONS		WARNING
<ul style="list-style-type: none"> Be sure to shut off all phases of the external power supply used by the system before mounting or removing the Multi-Drop Connection Unit to/from the panel. Not doing so can cause the unit to fail or malfunction. 		

MOUNTING PRECAUTIONS		WARNING
<ul style="list-style-type: none"> When installing the battery wear an earth band etc. to avoid the static electricity. The static electricity can cause the unit to fail or malfunction. 		

MOUNTING PRECAUTIONS		CAUTION
<ul style="list-style-type: none"> Use the Multi-Drop Connection Unit in the environment that satisfies the general specifications described in this manual. Not doing so can cause an electric shock, fire, malfunction or product damage or deterioration. 		

WIRING PRECAUTIONS		WARNING
<ul style="list-style-type: none"> Be sure to shut off all phases of the external power supply used by the system before wiring. Failure to do so may result in an electric shock, product damage or malfunctions. Please make sure to ground FG terminal of the Multi-Drop Connection Unit power supply section by applying 100 or less which is used exclusively for the GOT. Not doing so may cause an electric shock or malfunction. Correctly wire the Multi-Drop Connection Unit power supply section after confirming the rated voltage and terminal arrangement of the product. Not doing so can cause a fire or failure. Tighten the terminal screws of the Multi-Drop Connection Unit power supply section in the specified torque range. Undertightening can cause a short circuit or malfunction. Overtightening can cause a short circuit or malfunction due to the damage of the screws or the Multi-Drop Connection Unit. Exercise care to avoid foreign matter such as chips and wire offcuts entering the Multi-Drop Connection Unit. Not doing so can cause a fire, failure or malfunction. 		

WIRING PRECAUTIONS		CAUTION
<ul style="list-style-type: none"> Plug the communication cable into the connector of the connected unit and tighten the mounting and terminal screws in the specified torque range. Undertightening can cause a short circuit or malfunction. Overtightening can cause a short circuit or malfunction due to the damage of the screws or unit. 		

STARTUP/MAINTENANCE PRECAUTIONS		CAUTION
<ul style="list-style-type: none"> Do not disassemble or modify the Multi-Drop Connection Unit. Doing so can cause a failure, malfunction, injury or fire. Do not touch the conductive and electronic parts of the Multi-Drop Connection Unit directly. Doing so can cause a Multi-Drop Connection Unit malfunction or failure. The cables connected to the Multi-Drop Connection Unit must be run in ducts or clamped. Not doing so can cause the Multi-Drop Connection Unit or cable to be damaged due to the dangling, motion or accidental pulling of the cables or can cause a malfunction due to a cable connection fault. When unplugging the cable connected to the unit, do not hold and pull the cable portion. Doing so can cause the unit or cable to be damaged or can cause a malfunction due to a cable connection fault. Do not drop or apply any impact to the battery. If any impact has been applied, discard the battery and never use it. The battery may be damaged by the drop or impact. Before touching the unit, always touch grounded metal, etc. to discharge static electricity from human body, etc. Not doing so can cause the Multi-Drop Connection Unit to fail malfunction. 		

DISPOSAL PRECAUTIONS		CAUTION
<ul style="list-style-type: none"> When disposing of the product, handle it as industrial waste. 		

TRANSPORTATION PRECAUTIONS		CAUTION
<ul style="list-style-type: none"> Make sure to transport the Multi-Drop Connection Unit main unit and/or relevant unit(s) in the manner they will not be exposed to the impact exceeding the impact resistance described in the general specifications of this manual, as they are precision devices. Failure to do so may cause the unit to fail. Check if the unit operates correctly after transportation. 		

Compliance with EC directive (CE Marking)

This note does not guarantee that an entire mechanical module produced in accordance with the contents of this note will comply with the following standards. Compliance to EMC directive for the entire mechanical module should be checked by the user / manufacturer. For more details please contact the local Mitsubishi Electric sales site.

Attention

- This product is designed for use in industrial applications.

Requirement for Compliance with EMC directive

The following products have shown compliance through direct testing (to the identified standards) and design analysis (forming a technical construction file) to the European Directive for Electromagnetic Compatibility when used as directed by the appropriate documentation.

- This product is designed for use in industrial applications
 - Type: Graphic operation terminal
 - Models: GOT2000 series

Associated Manuals

The following manuals are relevant to this product. When these loose manuals are required, please consult with our local distributor.

Manual Name	Manual Number	Description
GOT2000 Series Connection Manual (Mitsubishi Electric Products) For GT Works3 Version1	SH-081197ENG	Describes system configurations of connection methods applicable to GOT2000 series and cable creation methods
GOT1000 Series Connection Manual 1/3, 2/3, 3/3	SH-080532ENG	Describes system configurations of connection methods applicable to GOT1000 series and cable creation methods
GOT1000 Series Connection Manual (Mitsubishi Products) for GT Works3	SH-080868ENG	Describes system configurations of connection methods applicable to GOT1000 series and cable creation methods
GT Designer2 Version2 Basic Operation/Data Transfer Manual (For GOT1000 Series)	SH-080529ENG	Describes methods of the GT Designer2 installation operation, basic operation for drawing and transmitting data to GOT1000 series
GT Designer2 Version2 Screen Design Manual (For GOT1000 Series) 1/3, 2/3, 3/3	SH-080530ENG	Describes specifications and settings of the object functions used in GT Designer2
GT Designer3 Version1 Screen Design Manual (For GOT1000 Series) (Fundamentals) 1/2, 2/2	SH-080866ENG	Describes methods of the GT Designer3 installation operation, basic operation for drawing and transmitting data to GOT1000 series
GT Designer3 (GOT2000) Screen Design Manual	SH-081220ENG	Describes methods of the GT Designer3 (GOT2000) installation operation, basic operation for drawing and transmitting data to GOT2000 series

Bundled Items


Included Item	Number of Items
GT01-RS4-M main unit	1
Power supply cable with connectors	1
GT01-RS4-M Serial Multi-Drop Connection Unit USER'S MANUAL (this manual)	1

1. System Configuration

1.1 System Configuration

GOT multi-drop connection is a communication method for 1:N communication by connecting multiple GOTs to one PLC, using the GT01-RS4-M serial multi-drop connection module.

For details of the system configuration, refer to the GOT1000 Series Connection Manual.



1.2 Compatible PLC

For PLCs compatible with the GOT multi-drop connection, refer to the GOT1000 Series Connection Manual.

Standard		Remark
EN61131-2 : 2007 Programmable controllers- Equipment, requirement and tests	EMI	Compliance with all relevant aspects of the standard. (Radiated Emissions)
	EMS	Compliance with all relevant aspects of the standard. (ESD, RF electromagnetic field, EFTB, Surge, RF conducted disturbances and Power frequency magnetic field)

For more details please contact the local Mitsubishi Electric sales site.

For details of CE marking, refer to the following.
→ **GOT2000 Series User's Manual (Hardware)**

Compliant with the UKCA marking

Requirements for compliance with the UKCA marking are the same with the EC Directives (CE marking).

1.3 Compatible GOT

The followings are the GOTs compatible with the GOT multi-drop connection. For the confirmation method of the hardware version, refer to the User's Manual of each GOT.

GOT	Hardware version
GOT2000 series ^{*1}	Version A or later
GT16□□, GT15□□	Version A or later
GT1455-QTBD, GT1450-QLBD GT1455-QTBDE, GT1450-QLBDE	Version A or later
GT1155-QTBD	Version C or later
GT1155-QSBD, GT1150-QLBD	Version F or later
GT1055-QSBD, GT1050-QBBD	Version C or later
GT1045-QSBD, GT1040-QBBD	Version A or later
GT1030-LBD/LWD, GT1030-LBDW/LWDW GT1030-HBD/HWD, GT1030-HBDW/HWDW	Version B or later
GT1020-LBD/LWD, GT1020-LBDW/LWDW	Version E or later

^{*1} For details on the GOT2000 series GOTs compatible with the GOT multi-drop connection, refer to the GOT2000 Series Connection Manuals.

1.4 Compatible drawing software version

<GOT1000 series>
GT Designer2 Version2 (Ver.2.93X or later)
GT Designer3 Version 1 1.01B or later (GT16 and GT15: Ver.1.14Q or later, GT14: Ver.1.37P or later)
<GOT2000 series>
With GT Designer3 (GOT2000), the standard monitor OS, communication drivers, and communication parameters cannot be written to the multi-drop connection module.
To use the GOT multi-drop connection with GOT2000, write the standard monitor OS, communication drivers, and communication parameters with GT Designer3 (GOT1000) (Version 1.14Q or later).


2. Outline Procedure

The outline procedure is shown below.
GT11 installation follows.


- 1) Install the OS.
- Install the communication driver of the PLC connected to the multi-drop connection module.
- Install the communication driver (multi-drop (Slave)) to the GOT.

For details on the installation method, refer to GT Designer2 Version2 Basic Operation/Data Transfer Manual or GT Designer3 Version1 Screen Design Manual (For GOT1000 Series).


- For GT Designer2
(For multi-drop connection module)




(For GOT)




- For GT Designer3
(For multi-drop connection module*1)




(For GOT)




- For GT Designer2
(For multi-drop connection module)




- For GT Designer3
(For multi-drop connection module*1)



(For GOT)



(For GOT)



*1 With GT Designer3 (GOT2000), the standard monitor OS and communication drivers cannot be written to the multi-drop connection module.
To use the GOT multi-drop connection with GOT2000, write the standard monitor OS and communication drivers with GT Designer3 (GOT1000) (Version 1.14Q or later).

- 2) Make sure that the OS is installed.
Check GT Designer2 or GT Designer3 drive information to know if the OS is properly installed in the GOT.
For details, refer to GT Designer2 Version2 Basic Operation/Data Transfer Manual or GT Designer3 Version1 Screen Design Manual (For GOT1000 Series).
- 3) Set the communication interface.
- For the multi-drop connection module, set the communication interface in the communication setting with GT01-RS4-M of GT Designer2 or GT Designer3.
- For the GOT, set the communication interface in the Communication Settings of GT Designer2 or GT Designer3.
For details, refer to GT Designer2 Version2 Basic Operation/Data Transfer Manual or GT Designer3 Version1 Screen Design Manual (For GOT1000 Series).

*1 With GT Designer3 (GOT2000), the communication parameters cannot be written to the multi-drop connection module.
To use the GOT multi-drop connection with GOT2000, write the communication parameters with GT Designer3 (GOT1000) (Version 1.14Q or later).

- 4) Download the project data.
For how to download project data, refer to GT Designer2 Version2 Basic Operation/Data Transfer Manual or GT Designer3 Version1 Screen Design Manual (For GOT1000 Series).
- 5) Connect the cable.
For details on the cable connection, refer to the GOT2000/GOT1000 Series Connection Manuals.

3. Specifications

3.1 General Specifications

Item	Specifications					
Operating ambient temperature	0 to 55°C					
Storage ambient temperature	-20 to 60°C					
Operating/Storage ambient humidity	10 to 90% RH, non-condensing (The wet bulb temperature is 39°C or less.)					
Vibration resistance	Conforms to JIS C60068-2-6		Frequency	Acceleration	Half-amplitude	Sweep Count
		Installed with DIN rail	10 to 57Hz	—	0.035mm	10 times each in X, Y and Z directions (Total 80 minutes for each)
			57 to 150Hz	4.9m/s ²	—	
		Directly installed	10 to 57Hz	—	0.075mm	
			57 to 150Hz	9.8m/s ²	—	
Shock resistance	Conforms to JIS C60068-2-27 (147 m/s ² , 11 ms, Sine half-wave pulse, 3 times each in the X, Y, and Z directions)					
Operating atmosphere	Must be free of lamp black, corrosive gas, flammable gas, or excessive amounts of electro conductive dust particles and must not be placed in direct sunlight. (This applies for storage as well)					
Operating altitude	2000m (6562 ft) max.*1					
Cooling method	Self-cooling					
External dimensions (D×W×H)	90×65×90mm					
Weight	Approx. 0.3kg					
Installation method	Using DIN rail or fixed with screws					
Exterior color (Case)	Standard color of Mitsubishi Electric (Black: corresponding to N-0230-BG)					
Standard	Conforms to CE					

*1 Cannot be used under pressures higher than the atmospheric pressure. Failure to observe this instruction may cause the unit to fail.

3.2 Communication Specifications

Item	I/F1 (RS-422)	I/F2 (RS-232)	I/F3 (RS-485)	I/F4 (USB)
Connection configuration	1:1		1:N	1:1
Transmission standard	Transmissi on method	RS-422 1ch	RS-232 1ch	RS-485 1ch
	Transmissi on speed	115, 200/57, 600/38, 400/19, 200/9, 600/4, 800 bps		Full Speed 12Mbps
	Insulation method	Photocoupler insulation		--
	Connector	D-sub 9-pin (female)	D-sub 9-pin (male)	Terminal block (attach/detach type)
Transmission distance	30m or less	3m or less	500m (max.) (maximum overall extension length of the system)	--
Number of GOTs that can be connected	1		16 (max.)	1
Communication method	Full duplex		Half duplex and full duplex (Can be selected depending on the wiring)	--
Application	For PLC connection (Cannot be used simultaneously with I/F2)	For PLC connection (Cannot be used simultaneously with I/F1)	For multi-drop connection	PC communication (OS installation)

3.3 Power Supply Specifications


Item	Specifications
Input power supply voltage	24VDC (+10%, -15%)
Fuse (built-in, not exchangeable)	1A
Power consumption	3.36W or less (140mA/24VDC)
Inrush current	14A or less (24VDC, 2ms)
Dielectric withstand voltage	500VAC for 1 minute (across power supply terminals and earth)
Insulation resistance	10MΩ or larger by insulation resistance tester (across power supply terminals and earth)
Grounding	Class D grounding (100Ω or less). To be connected to the panel when grounding is not possible

3.4 LED Light Specifications

LED Name	Status	Description
POWER	Lit	Power is properly supplied.
	Not lit	Power is not properly supplied.
SD	Lit	Sending the data to PLC
	Not lit	Not sending the data to PLC
RD	Lit	Receiving the data from PLC
	Not lit	Not receiving the data from PLC
ERROR*1	Not lit	No error
	Lit in red	Communication error with PLC
	Blinking in red	Multi-drop communication error

*1 For details of corrective actions, refer to Chapter 7 Troubleshooting.

4. External Dimensions and Part name



No	Name	Specifications
1)	Installation hole for the main unit	Installation hole
2)	LED	POWER Lit in green when the power is properly supplied.
		SD Lit in green when the data is being sent to PLC.
		RD Lit in green when the data is being received from PLC.
		ERROR Lit or blinking depending on the status.
3)	Terminating resistor selector	Can be selected among 110Ω, OPEN and 330Ω (set to "OPEN" by default)
4)	Connector for PLC communication (for RS-232 connection)	D-sub 9-pin (male)
5)	Connector selection switch for PLC communication	Switch for selecting RS-422 or RS-232 (set to "RS-422" by default)
6)	USB port	For connecting to a personal computer (for changing the communication driver)
7)	Connector for PLC communication (for RS-422 connection)	D-sub 9-pin (female)
8)	Protective cover	Protect unused D-sub connector, USB port and switches.
9)	Terminal block for the serial multi-drop communication	Terminal block 5-pin (with a protective cover) M3 Tightening torque 0.5 to 0.6N.m
10)	Power supply connector	24VDC power supply connector insertion point (A dedicated cable is included.)
11)	Slider for installing the DIN rail	—
12)	Mode selection switch (Slide switch)	Do not operate. (Set to right by default. When set to left, the module does not operate normally.)

5. Installation

5.1 Installed with DIN Rail

Install the multi-drop connection module with its hook (1 place) using the DIN rail.

- Applicable DIN rail DIN46277 (width: 35mm)
(Install the DIN rail with screws at intervals of 150mm.)

5.2 Directly Installed to Panel

Install the multi-drop connection module to the panel using $\phi 4.5$ mm holes (2 places).


5.3 Caution for compliance with EMC Directive

Programmable logic controllers are open-type devices that must be installed and used within conductive control boxes. Please use the Multi-Drop Connection Unit while installed in conductive shielded control boxes. Please secure the control box lid to the control box (for conduction). Installation within a control box greatly affects the safety of the system and aids in shielding noise from the Multi-Drop Connection Unit.

6. Wiring

6.1 Power Supply Wiring


Connect the power supply cable with connectors (included) and the 24VDC terminal of the external power supply.



6.2 Wiring and Terminating Resistor Setting

6.2.1 For 1 pair wiring


Make sure to ground a twisted pair cable by applying Class D Grounding (100 Ω or less).



*1 The terminating resistor (110 Ω) is built in the multi-drop connection module and GOT (GT21, GT10, GT11, or GT14). Make sure to set it on both ends of the line. For GT27, GT25, GT15, and GT16, external wiring is required. Set the terminating resistors of the GOT that is not at the end of the line to "OPEN".

6.2.2 For 2 pair wiring

Make sure to ground a twisted pair cable by applying Class D Grounding (100 Ω or less).



*1 The terminating resistors (330 Ω) are built in the multi-drop connection module and GOT (GT21, GT10, GT11, or GT14). Make sure to set them on both ends of the line. For GT27, GT25, GT15, and GT16, external wiring is required. Set the terminating resistors of the GOT that is not at the end of the line to "OPEN".

7. Troubleshooting

In the case where ERROR LED is lit or blinking, check the following items.

Status of ERROR LED	Description
Lit in red	<p>Check the following items.</p> <ul style="list-style-type: none">Check if the power supply status is normal or not.Check the wiring of the connection cable.Install the correct communication driver.Check if the communication interface to which the cable is connected is correct or not.Check the setting of the RS-422/RS-232 selector switch.
Blinking in red	<p>Check the following items.</p> <ul style="list-style-type: none">Check that the Mode selection switch is set to the right.The OS may be faulty. Install the standard OS and communication driver from GT Designer2 or GT Designer3*1 to the multi-drop module again.

*1 With GT Designer3 (GOT2000), the standard monitor OS and communication drivers cannot be written.
To use the GOT multi-drop connection with GOT2000, write the standard monitor OS and communication drivers with GT Designer3 (GOT1000) (Version 1.14Q or later).

「电器电子产品有害物质限制使用标识要求」的表示方式



Note: This symbol mark is for China only.

含有有害 10 物质的名称、含有量、含有部件
本产品中所含有的有害 10 物质的名称、含有量、含有部件如下表所示。

产品中有害物质的名称及含量							
部件名称		有害物质					
		铅 (Pb)	汞 (Hg)	镉 (Cd)	六价铬 (Cr (VI))	多溴联苯 (PBB)	多溴 二苯醚 (PBDE)
显示器 GOT	外壳	○	○	○	○	○	○
	印刷基板	×	○	○	○	○	○
	电缆	×	○	○		○	○
部件名称		有害物质					
		邻苯二甲酸二 (2-乙基) 己酯 (DEHP)	邻苯二甲酸二 正丁酯 (DBP)	邻苯二甲酸丁 苯酯 (BBP)	邻苯二甲酸 异丁酯 (DIBP)		
显示器 GOT	外壳	○	○	○	○	○	○
	印刷基板	○	○	○	○	○	○
	电缆	○	○	○	○		○

本表格依据 SJ/T 11364 的规定编制。
○：表示该有害物质在该部件所有均质材料中的含量均在 GB/T 26572 规定的限量要求以下。
×：表示该有害物质至少在该部件的某一均质材料中的含量超出 GB/T 26572 规定的限量要求。

Referenced Standard

GB/T 15969.2 (Requirement of Chinese standardized law)

This manual confers no industrial property rights or any rights of any other kind, nor does it confer any patent licenses. Mitsubishi Electric Corporation cannot be held responsible for any problems involving industrial property rights which may occur as a result of using the contents noted in this manual.

Warranty
Exclusion of loss in opportunity and secondary loss from warranty liability
Regardless of the gratis warranty term, Mitsubishi Electric shall not be liable for compensation to:
(1) Damages caused by any cause found not to be the responsibility of Mitsubishi Electric.
(2) Loss in opportunity, lost profits incurred to the user by Failures of Mitsubishi Electric products.
(3) Special damages and secondary damages whether foreseeable or not, compensation for accidents, and compensation for damages to products other than Mitsubishi Electric products.
(4) Replacement by the user, maintenance of on-site equipment, start-up test run and other tasks.

For safe use

- This product has been manufactured as a general-purpose part for general industries, and has not been designed or manufactured to be incorporated in a device or system used in purposes related to human life.
- Before using the product for special purposes such as nuclear power, electric power, aerospace, medicine or passenger movement vehicles, consult with Mitsubishi Electric.
- This product has been manufactured under strict quality control. However when installing the product where major accidents or losses could occur if the product fails, install appropriate backup or failsafe functions in the system.

MITSUBISHI ELECTRIC CORPORATION

HEAD OFFICE : TOKYO BLDG., 2-7-3 MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN



GT01-RS4-M Serial Multi-Drop Connection Unit

User's Manual



Manual Number	JY997D35801K
Date	Nov. 2025

This manual describes the specifications of the product. Before use, read this manual and manuals of relevant products fully to acquire proficiency in handling and operating the product. Make sure to learn all the product information, safety information, and precautions.

And, store this manual in a safe place so that you can take it out and read it whenever necessary. Always forward it to the end user.

Registration

The company name and the product name to be described in this manual are the registered trademarks or trademarks of each company.

Effective Nov. 2025
Specifications are subject to change without notice.
© 2009 MITSUBISHI ELECTRIC CORPORATION

Safety Precaution (Read these precautions before using.)

Before using this product, please read this manual and the relevant manuals introduced in this manual carefully and pay full attention to safety to handle the product correctly.

The precautions given in this manual are concerned with this product.

In this manual, the safety precautions are ranked as "WARNING" and "CAUTION".

WARNING	Indicates that incorrect handling may cause hazardous conditions, resulting in death or severe injury.
CAUTION	Indicates that incorrect handling may cause hazardous conditions, resulting in medium or slight personal injury or physical damage.

Depending on circumstances, procedures indicated by "CAUTION" may also be linked to serious results.

In any case, it is important to follow the directions for usage.

DESIGN PRECAUTIONS WARNING

- Some failures of the Multi-Drop Connection Unit or cable may keep the outputs on or off.
- An external monitoring circuit should be provided to check for output signals which may lead to a serious accident.
- Not doing so can cause an accident due to false output or malfunction.
- If a communication fault (including cable disconnection) occurs during monitoring on the GOT, communication between the GOT and PLC CPU is suspended and the GOT becomes inoperative.
- A system where the GOT is used should be configured to perform any significant operation to the system by using the switches of a device other than the GOT on the assumption that a GOT communication fault will occur.
- Not doing so can cause an accident due to false output or malfunction.
- Do not use the Multi-Drop Connection Unit as the warning device that may cause a serious accident.
- An independent and redundant hardware or mechanical interlock is required to configure the device that displays and outputs serious warning.
- Failure to observe this instruction may result in an accident due to incorrect output or malfunction.

DESIGN PRECAUTIONS CAUTION

- Do not bundle the control and communication cables with main-circuit, power or other wiring.
- Run the above cables separately from such wiring and keep them a minimum of 100mm (3.94in.) apart. Not doing so noise can cause a malfunction.

MOUNTING PRECAUTIONS WARNING

- Be sure to shut off all phases of the external power supply used by the system before mounting or removing the Multi-Drop Connection Unit to/from the panel.
- Not doing so can cause the unit to fail or malfunction.

MOUNTING PRECAUTIONS WARNING

- When installing the battery wear an earth band etc. to avoid the static electricity. The static electricity can cause the unit to fail or malfunction.

MOUNTING PRECAUTIONS CAUTION

- Use the Multi-Drop Connection Unit in the environment that satisfies the general specifications described in this manual. Not doing so can cause an electric shock, fire, malfunction or product damage or deterioration.

WIRING PRECAUTIONS WARNING

- Be sure to shut off all phases of the external power supply used by the system before wiring. Failure to do so may result in an electric shock, product damage or malfunctions.
- Please make sure to ground FG terminal of the Multi-Drop Connection Unit power supply section by applying 100 or less which is used exclusively for the GOT. Not doing so may cause an electric shock or malfunction.
- Correctly wire the Multi-Drop Connection Unit power supply section after confirming the rated voltage and terminal arrangement of the product. Not doing so can cause a fire or failure.
- Tighten the terminal screws of the Multi-Drop Connection Unit power supply section in the specified torque range. Undertightening can cause a short circuit or malfunction.
- Overlightening can cause a short circuit or malfunction due to the damage of the screws or the Multi-Drop Connection Unit.
- Exercise care to avoid foreign matter such as chips and wire offcuts entering the Multi-Drop Connection Unit. Not doing so can cause a fire, failure or malfunction.

WIRING PRECAUTIONS CAUTION

- Plug the communication cable into the connector of the connected unit and tighten the mounting and terminal screws in the specified torque range.
- Underlightening can cause a short circuit or malfunction. Overlightening can cause a short circuit or malfunction due to the damage of the screws or unit.

STARTUP/MAINTENANCE PRECAUTIONS CAUTION

- Do not disassemble or modify the Multi-Drop Connection Unit.
- Doing so can cause a failure, malfunction, injury or fire.
- Do not touch the conductive and electronic parts of the Multi-Drop Connection Unit directly.
- Doing so can cause a Multi-Drop Connection Unit malfunction or failure.
- The cables connected to the Multi-Drop Connection Unit must be run in ducts or clamped.
- Not doing so can cause the Multi-Drop Connection Unit or cable to be damaged due to the dangling, motion or accidental pulling of the cables or can cause a malfunction due to a cable connection fault.
- When unplugging the cable connected to the unit, do not hold and pull the cable portion. Doing so can cause the unit or cable to be damaged or can cause a malfunction due to a cable connection fault.
- Do not drop or apply any impact to the battery.
- If any impact has been applied, discard the battery and never use it.
- The battery may be damaged by the drop or impact.
- Before touching the unit, always touch grounded metal, etc. to discharge static electricity from human body, etc.
- Not doing so can cause the Multi-Drop Connection Unit to fail malfunction.

DISPOSAL PRECAUTIONS CAUTION

- When disposing of the product, handle it as industrial waste.

TRANSPORTATION PRECAUTIONS CAUTION

- Make sure to transport the Multi-Drop Connection Unit main unit and/or relevant unit(s) in the manner they will not be exposed to the impact exceeding the impact resistance described in the general specifications of this manual, as they are precision devices. Failure to do so may cause the unit to fail.
- Check if the unit operates correctly after transportation.

Compliance with EC directive (CE Marking)

This note does not guarantee that an entire mechanical module produced in accordance with the contents of this note will comply with the following standards. Compliance to EMC directive for the entire mechanical module should be checked by the user / manufacturer. For more details please contact the local Mitsubishi Electric sales site.

Attention

- This product is designed for use in industrial applications.

Requirement for Compliance with EMC directive

The following products have shown compliance through direct testing (to the identified standards) and design analysis (forming a technical construction file) to the European Directive for Electromagnetic Compatibility when used as directed by the appropriate documentation.

- This product is designed for use in industrial applications
 - Type: Graphic operation terminal
 - Models: GOT2000 series

Standard		Remark
EN61131-2 : 2007 Programmable controllers- Equipment, requirement and tests	EMI	Compliance with all relevant aspects of the standard. (Radiated Emissions)
	EMS	Compliance with all relevant aspects of the standard. (ESD, RF electromagnetic field, EFTB, Surge, RF conducted disturbances and Power frequency magnetic field)

For more details please contact the local Mitsubishi Electric sales site.
For details of CE marking, refer to the following.
→ **GOT2000 Series User's Manual (Hardware)**

Compliant with the UKCA marking

Requirements for compliance with the UKCA marking are the same with the EC Directives (CE marking).

Associated Manuals

The following manuals are relevant to this product. When these loose manuals are required, please consult with our local distributor.

Manual Name	Manual Number	Description
GOT2000 Series Connection Manual (Mitsubishi Electric Products) For GT Works3 Version1	SH-081197ENG	Describes system configurations of connection methods applicable to GOT2000 series and cable creation methods
GOT1000 Series Connection Manual 1/3, 2/3, 3/3	SH-080532ENG	Describes system configurations of connection methods applicable to GOT1000 series and cable creation methods
GOT1000 Series Connection Manual (Mitsubishi Products) for GT Works3	SH-080868ENG	Describes system configurations of connection methods applicable to GOT1000 series and cable creation methods
GT Designer2 Version2 Basic Operation/Data Transfer Manual (For GOT1000 Series)	SH-080529ENG	Describes methods of the GT Designer2 installation operation, basic operation for drawing and transmitting data to GOT1000 series
GT Designer2 Version2 Screen Design Manual (For GOT1000 Series) 1/3, 2/3, 3/3	SH-080530ENG	Describes specifications and settings of the object functions used in GT Designer2
GT Designer3 Version1 Screen Design Manual (For GOT1000 Series) (Fundamentals) 1/2, 2/2	SH-080866ENG	Describes methods of the GT Designer3 installation operation, basic operation for drawing and transmitting data to GOT1000 series
GT Designer3 (GOT2000) Screen Design Manual	SH-081220ENG	Describes methods of the GT Designer3 (GOT2000) installation operation, basic operation for drawing and transmitting data to GOT2000 series

Bundled Items


Included Item	Number of Items
GT01-RS4-M main unit	1
Power supply cable with connectors	1
GT01-RS4-M Serial Multi-Drop Connection Unit USER'S MANUAL (this manual)	1

1. System Configuration

1.1 System Configuration

GOT multi-drop connection is a communication method for 1:N communication by connecting multiple GOTs to one PLC, using the GT01-RS4-M serial multi-drop connection module.

For details of the system configuration, refer to the GOT1000 Series Connection Manual.



1.2 Compatible PLC

For PLCs compatible with the GOT multi-drop connection, refer to the GOT1000 Series Connection Manual.

1.3 Compatible GOT

The followings are the GOTs compatible with the GOT multi-drop connection. For the confirmation method of the hardware version, refer to the User's Manual of each GOT.

GOT	Hardware version
GOT2000 series*1	Version A or later
GT16□□, GT15□□	Version A or later
GT1455-QTBD, GT1450-QLBD GT1455-QTBDE, GT1450-QLBDE	Version A or later
GT1155-QTBD	Version C or later
GT1155-QSBD, GT1150-QLBD	Version F or later
GT1055-QSBD, GT1050-QBBD	Version C or later
GT1045-QSBD, GT1040-QBBD	Version A or later
GT1030-LBD/LWD, GT1030-LBDW/LWDW GT1030-HBD/HWD, GT1030-HBDW/HWDW	Version B or later
GT1020-LBD/LWD, GT1020-LBDW/LWDW	Version E or later

*1 For details on the GOT2000 series GOTs compatible with the GOT multi-drop connection, refer to the GOT2000 Series Connection Manuals.

1.4 Compatible drawing software version

<GOT1000 series>
GT Designer2 Version2 (Ver.2.93X or later)
GT Designer3 Version 1 1.01B or later (GT16 and GT15: Ver.1.14Q or later, GT14: Ver.1.37P or later)
<GOT2000 series>
With GT Designer3 (GOT2000), the standard monitor OS, communication drivers, and communication parameters cannot be written to the multi-drop connection module.
To use the GOT multi-drop connection with GOT2000, write the standard monitor OS, communication drivers, and communication parameters with GT Designer3 (GOT1000) (Version 1.14Q or later).

2. Outline Procedure


The outline procedure is shown below.

GT11 installation follows.


- 1) Install the OS.
- 2) Install the communication driver of the PLC connected to the multi-drop connection module.
- 3) Install the communication driver (multi-drop (Slave)) to the GOT.

For details on the installation method, refer to GT Designer2 Version2 Basic Operation/Data Transfer Manual or GT Designer3 Version1 Screen Design Manual (For GOT1000 Series).


- For GT Designer2 (For multi-drop connection module)




(For GOT)




- For GT Designer3 (For multi-drop connection module*1)




(For GOT)




- For GT Designer2 (For multi-drop connection module)




(For GOT)



- For GT Designer3 (For multi-drop connection module*1)



(For GOT)



*1 With GT Designer3 (GOT2000), the standard monitor OS and communication drivers cannot be written to the multi-drop connection module.
To use the GOT multi-drop connection with GOT2000, write the standard monitor OS and communication drivers with GT Designer3 (GOT1000) (Version 1.14Q or later).

- 2) Make sure that the OS is installed.
Check GT Designer2 or GT Designer3 drive information to know if the OS is properly installed in the GOT.
For details, refer to GT Designer2 Version2 Basic Operation/Data Transfer Manual or GT Designer3 Version1 Screen Design Manual (For GOT1000 Series).
- 3) Set the communication interface.
For the multi-drop connection module, set the communication interface in the communication setting with GT01-RS4-M of GT Designer2 or GT Designer3.
For the GOT, set the communication interface in the Communication Settings of GT Designer2 or GT Designer3.
For details, refer to GT Designer2 Version2 Basic Operation/Data Transfer Manual or GT Designer3 Version1 Screen Design Manual (For GOT1000 Series).

3. Specifications

3.1 General Specifications

Item	Specifications					
Operating ambient temperature	0 to 55°C					
Storage ambient temperature	-20 to 60°C					
Operating/Storage ambient humidity	10 to 90% RH, non-condensing (The wet bulb temperature is 39°C or less.)					
Vibration resistance	Conforms to JIS C60068-2-6		Frequency	Acceleration	Half-amplitude	Sweep Count
		Installed with DIN rail	10 to 57Hz	—	0.035mm	10 times each in X, Y and Z directions (Total 80 minutes for each)
			57 to 150Hz	4.9m/s ²	—	
		Directly installed	10 to 57Hz	—	0.075mm	
		57 to 150Hz	9.8m/s ²	—		
Shock resistance	Conforms to JIS C60068-2-27 (147 m/s ² , 11 ms, Sine half-wave pulse, 3 times each in the X, Y, and Z directions)					
Operating atmosphere	Must be free of lamp black, corrosive gas, flammable gas, or excessive amounts of electro conductive dust particles and must not be placed in direct sunlight. (This applies for storage as well)					
Operating altitude	2000m (6562 ft) max. *1					
Cooling method	Self-cooling					
External dimensions (D×W×H)	90×65×90mm					
Weight	Approx. 0.3kg					
Installation method	Using DIN rail or fixed with screws					
Exterior color (Case)	Standard color of Mitsubishi Electric (Black: corresponding to N-0230-BG)					
Standard	Conforms to CE					

*1 Cannot be used under pressures higher than the atmospheric pressure. Failure to observe this instruction may cause the unit to fail.

3.2 Communication Specifications

Item	I/F1 (RS-422)		I/F2 (RS-232)	I/F3 (RS-485)	I/F4 (USB)
Connection configuration	1:1			1:N	1:1
Transmission standard	Transmission method	RS-422 1ch	RS-232 1ch	RS-485 1ch	USB device 1ch
	Transmission speed	115, 200/57, 600/38, 400/19, 200/9, 600/4, 800 bps			Full Speed 12Mbps
	Insulation method	Photocoupler insulation			--
	Connector	D-sub 9-pin (female)	D-sub 9-pin (male)	Terminal block (attach/detach type)	Mini-B
Transmission distance	30m or less		3m or less	500m (max.) (maximum overall extension length of the system)	--
Number of GOTs that can be connected	1			16 (max.)	1
Communication method	Full duplex			Half duplex and full duplex (Can be selected depending on the wiring)	--
Application	For PLC connection (Cannot be used simultaneously with I/F2)		For PLC connection (Cannot be used simultaneously with I/F1)	For multi-drop connection	PC communication (OS installation)

3.3 Power Supply Specifications

Item	Specifications
Input power supply voltage	24VDC (+10%, -15%)
Fuse (built-in, not exchangeable)	1A
Power consumption	3.36W or less (140mA/24VDC)
Inrush current	14A or less (24VDC, 2ms)
Dielectric withstand voltage	500VAC for 1 minute (across power supply terminals and earth)
Insulation resistance	10MΩ or larger by insulation resistance tester (across power supply terminals and earth)
Grounding	Class D grounding (100Ω or less), To be connected to the panel when grounding is not possible

5. Installation

5.1 Installed with DIN Rail

Install the multi-drop connection module with its hook (1 place) using the DIN rail.

- Applicable DIN rail DIN46277 (width: 35mm)
(Install the DIN rail with screws at intervals of 150mm.)

5.2 Directly Installed to Panel

Install the multi-drop connection module to the panel using φ4.5mm holes (2 places).


5.3 Caution for compliance with EMC Directive

Programmable logic controllers are open-type devices that must be installed and used within conductive control boxes. Please use the Multi-Drop Connection Unit while installed in conductive shielded control boxes. Please secure the control box lid to the control box (for conduction). Installation within a control box greatly affects the safety of the system and aids in shielding noise from the Multi-Drop Connection Unit.

6. Wiring

6.1 Power Supply Wiring


Connect the power supply cable with connectors (included) and the 24VDC terminal of the external power supply.



6.2 Wiring and Terminating Resistor Setting

6.2.1 For 1 pair wiring

Make sure to ground a twisted pair cable by applying Class D Grounding (100Ω or less).




*1 The terminating resistor (110Ω) is built in the multi-drop connection module and GOT (GT21, GT10, GT11, or GT14). Make sure to set it on both ends of the line. For GT27, GT25, GT15, and GT16, external wiring is required. Set the terminating resistors of the GOT that is not at the end of the line to "OPEN".

3.4 LED Light Specifications

LED Name	Status	Description
POWER	Lit	Power is properly supplied.
	Not lit	Power is not properly supplied.
SD	Lit	Sending the data to PLC
	Not lit	Not sending the data to PLC
RD	Lit	Receiving the data from PLC
	Not lit	Not receiving the data from PLC
ERROR*1	Not lit	No error
	Lit in red	Communication error with PLC
	Blinking in red	Multi-drop communication error

*1 For details of corrective actions, refer to Chapter 7 Troubleshooting.


4. External Dimensions and Part name



No	Name	Specifications
1)	Installation hole for the main unit	Installation hole
2)	LED	POWER Lit in green when the power is properly supplied.
		SD Lit in green when the data is being sent to PLC.
		RD Lit in green when the data is being received from PLC.
		ERROR Lit or blinking depending on the status.
3)	Terminating resistor selector	Can be selected among 110Ω, OPEN and 330Ω (set to "OPEN" by default)
4)	Connector for PLC communication (for RS-232 connection)	D-sub 9-pin (male)
5)	Connector selection switch for PLC communication	Switch for selecting RS-422 or RS-232 (set to "RS-422" by default)
6)	USB port	For connecting to a personal computer (for changing the communication driver)
7)	Connector for PLC communication (for RS-422 connection)	D-sub 9-pin (female)
8)	Protective cover	Protect unused D-sub connector, USB port and switches.
9)	Terminal block for the serial multi-drop communication	Terminal block 5-pin (with a protective cover) M3 Tightening torque 0.5 to 0.6N.m
10)	Power supply connector	24VDC power supply connector insertion point (A dedicated cable is included.)
11)	Slider for installing the DIN rail	–
12)	Mode selection switch (Slide switch)	Do not operate. (Set to right by default. When set to left, the module does not operate normally.)

6.2.2 For 2 pair wiring

Make sure to ground a twisted pair cable by applying Class D Grounding (100Ω or less).



*1 The terminating resistors (330Ω) are built in the multi-drop connection module and GOT (GT21, GT10, GT11, or GT14). Make sure to set them on both ends of the line. For GT27, GT25, GT15, and GT16, external wiring is required. Set the terminating resistors of the GOT that is not at the end of the line to "OPEN".

7. Troubleshooting

In the case where ERROR LED is lit or blinking, check the following items.

Status of ERROR LED	Description
Lit in red	Check the following items. <ul style="list-style-type: none">Check if the power supply status is normal or not.Check the wiring of the connection cable.Install the correct communication driver.Check if the communication interface to which the cable is connected is correct or not.Check the setting of the RS-422/RS-232 selector switch.
Blinking in red	Check the following items. <ul style="list-style-type: none">Check that the Mode selection switch is set to the right.The OS may be faulty. Install the standard OS and communication driver from GT Designer2 or GT Designer3*1 to the multi-drop module again.

*1 With GT Designer3 (GOT2000), the standard monitor OS and communication drivers cannot be written. To use the GOT multi-drop connection with GOT2000, write the standard monitor OS and communication drivers with GT Designer3 (GOT1000) (Version 1.14Q or later).

「电器电子产品有害物质限制使用标识要求」的表示方式



Note: This symbol mark is for China only.

含有有害 10 物质的名称、含有量、含有部件
本产品中所含有的有害 10 物质的名称、含有量、含有部件如下表所示。

产品中有害物质的名称及含量						
部件名称	有害物质					
	铅 (Pb)	汞 (Hg)	镉 (Cd)	六价铬 (Cr (VI))	多溴联苯 (PBB)	多溴二苯醚 (PBDE)
显示器 GOT	外壳	○	○	○	○	○
	印刷基板	×	○	○	○	○
	电缆	×	○	○	○	○
部件名称	有害物质					
	邻苯二甲酸二 (2-乙基) 己酯 (DEHP)	邻苯二甲酸二 正丁酯 (DBP)	邻苯二甲酸丁 苯酯 (BBP)	邻苯二甲酸二 异丁酯 (DIBP)		
显示器 GOT	外壳	○	○	○		
	印刷基板	○	○	○		
	电缆	○	○	○		

本表格依据 SJ/T 11364 的规定编制。
○：表示该有害物质在该部件所有均质材料中的含量均在 GB/T 26572 规定的限量要求以下。
×：表示该有害物质至少在该部件的某一均质材料中的含量超出 GB/T 26572 规定的限量要求。

Referenced Standard

GB/T 15969.2 (Requirement of Chinese standardized law)

This manual confers no industrial property rights or any rights of any other kind, nor does it confer any patent licenses. Mitsubishi Electric Corporation cannot be held responsible for any problems involving industrial property rights which may occur as a result of using the contents noted in this manual.

Warranty
Exclusion of loss in opportunity and secondary loss from warranty liability
Regardless of the gratis warranty term, Mitsubishi Electric shall not be liable for compensation to:
(1) Damages caused by any cause found not to be the responsibility of Mitsubishi Electric.
(2) Loss in opportunity, lost profits incurred to the user by Failures of Mitsubishi Electric products.
(3) Special damages and secondary damages whether foreseeable or not, compensation for accidents, and compensation for damages to products other than Mitsubishi Electric products.
(4) Replacement by the user, maintenance of on-site equipment, start-up test run and other tasks.

For safe use

- This product has been manufactured as a general-purpose part for general industries, and has not been designed or manufactured to be incorporated in a device or system used in purposes related to human life.
- Before using the product for special purposes such as nuclear power, electric power, aerospace, medicine or passenger movement vehicles, consult with Mitsubishi Electric.
- This product has been manufactured under strict quality control. However when installing the product where major accidents or losses could occur if the product fails, install appropriate backup or failsafe functions in the system.

MITSUBISHI ELECTRIC CORPORATION

HEAD OFFICE : TOKYO BLDG., 2-7-3 MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN